

Generator Set Data Sheet	Model:	C275D6
	Frequency:	60
	Fuel Type:	Diesel

Exhaust Emission Data Sheet:	TBC
Emissions Compliance Sheet:	TBC
Measured Sound Performance Data Sheet:	TBC
Measured Cooling Performance Data Sheet:	TBC
Prototype Test Summary Data Sheet:	TBC

		Standby					Prime		
Fuel Consumption		kW (kVA)					kW (kVA)		
	Ratings		275 (344)		250 (312)				
	Load	1/4	1/2	3/4	Full	1/4	1/2	3/4	Full
	US gph	5.8	10.4	15.7	21.6	4.9	8.8	13.2	18.2
	L/hr	21.8	39.2	59.8	81.6	18.3	33	50.4	68.8

	Standby	Prime		
Engine	Rating	Rating		
Engine Manufacturer	Cummins			
Engine Model	QSL9 (
Configuration	4-Cycle; In-line; 6-0	Cylinder Diesel		
Aspiration	Turbo Charged			
Gross Engine Power Output, kWm (bhp)	355 (476)	307 (412)		
BMEP at Set Rated Load, kPa (psi)	2668 (387)	2309 (335)		
Bore, mm	114			
Stroke, mm	145			
Rated Speed, rpm	1800			
Piston Speed, m/s (ft/min)	8.7 (17	07)		
Compression Ratio	16.8 : 1			
Lube Oil Capacity, L (US gph)	26.5 (7)			
Overspeed Limit, rpm	2100			
Regenerative Power, kW	47			
Fuel Flow				
Maximum Fuel Flow, L/hr (US gph)	165 (4	3)		
Maximum Fuel Inlet Restriction, mm Hg, (in Hg)	152 (6			
Maximum Fuel Return Line Restriction, mm Hg (in Hg)	254 (1	0)		
Maximum Fuel inlet temperature, °C (°F)	70 (160)			
Combustion Air				
Combustion Air, L/s (cfm)	410 (870)	390 (820)		
Maximum Air Cleaner Restriction, mm H2o (in H2O)	635 (2	5)		
Exhaust				
Exhaust Gas Flow at Set Rated Load, L/s (cfm)	640 (1355)	600 (1270)		
Exhaust Gas Temperature, °C (°F)	580 (1070)	500 (945)		
Maximum Exhaust Back Pressure, mmHg (in Hg)	76 (3)		

Standard Set-Mounted Radiator Cooling	Standby Rating	Prime Rating	
Ambient Design, °C (°F)	50		
Fan Load, KW _m (HP)	11 (14.:	3)	
Coolant Capacity (with Radiator), L (US Gal.)	28.6 (7.6)		
Cooling System Air Flow, m ³ /s (scfm)	9.44 (200	002)	
Total Heat Rejection, kW (BTU/min)	275 (15638)	233 (13290)	
Maximum Cooling Air Flow Static Restriction, mm H2o (in. H2o)	12.5 (0.	5)	

Weights* (Narrow Baseframe)	
Unit Dry Weight kgs	2342
Unit Wet Weight kgs	2907

^{*} Weights represent a set with standard features. See outline drawing for weights of other configurations

Derating Factors (kW, kVA)

Note: Standard genset options running at 440V, 150m above sea level.

	27°C	40°C	45°C	50°C	55°C
Standby	275	275	275	275	275
Prime	250	250	250	250	250

Ratings Definitions

Standby: Prime (Unlimited Running Time): Base Load (Continuous): Applicable for supplying emergency power Applicable for supplying power in lieu of Applicable for supplying power continuously for the duration of normal power commercially purchased power. Prime to a constant load up to the full output rating power is the maximum power available at a for unlimited hours. No sustained overload interruption. No sustained overload capability is available for this rating. This variable load for an unlimited number of capability is available for this rating. Consult rating is applicable to installations served by hours. A 10% overload capability is authorized distributor for rating. (Equivalent a reliable normal utility source. This rating available for limited time. (Equivalent to to Continuous Power in accordance with Prime Power in accordance with ISO8528 is only applicable to variable loads with an ISO8528, ISO3046, AS2789, DIN6271, average load factor of 80 percent of the and Overload Power in accordance with and BS5514). This rating is not applicable standby rating for a maximum of 200 hours ISO3046, AS2789, DIN6271, and to all generator set models. BS5514). This rating is not applicable to all of operation per year and a maximum of 25 hours per year at 100% of its standby generator set models. rating. The standby rating is only applicable to emergency and standby applications where the generator set serves as the back up to the normal utility source. No sustained utility parallel operation is permitted with this rating. (Equivalent to Fuel Stop Power in accordance with ISO3046, AS2789, DIN6271 and BS5514). Nominally Rated.

Voltage	Connection ¹	Temp Rise Degrees C	Duty ²	Single Phase Factor ³	Winding No.	Feature Code
416-480V	WYE	150/125	S/P	N/A	311	B682

Notes:

- Limited single phase capability is available from some three phase rated configurations. To obtain single phase rating, multipy the three
 phase kW rating by the Single Phase Factor³. All single phase ratings are at unity power factor.
- 2. Standby (S), Prime (P) and (C) Continuous ratings.
- 3. Factor for the Single Phase Output from Three Phase Alternator formula listed below
- 4. Maximum rated starting kVA that results in a minimum of 90% of rated sustained voltage during starting.

Formulas for calculating full load currents:

Three Phase Output	Single Phase Output
kWx1000	kWxSingleP haseFactor x1000
Voltagex1.73x0.8	Voltage

See your distributor for more information.



Cummins Power Generation Manston Park, Columbus Avenue Manston, Ramsgate Kent CT12 5BF, UK Telephone: +44 (0) 1843 255000 Fax: +44 (0) 1843 255902 E-Mail: cpg.uk@cummins.com Web: www.cumminspower.com

Cummins and PowerCommand are registered trademarks of Cummins Inc. AmpSentry is a trademark of Cummins Inc.

Important: Back feed to a utility system can cause electrocution and/or property damage. Do not connect to any building's electrical system except through an approved device or after building main switch is open.